7100 PARK RIDGE BL.

6812

6816

SERVICE STATION

6700 NAVAJO RD.

CAR PORT

ALARM RESET

6824

6832

6836

6808

6828

PARKING

6804

6840

6856

HYDE PARK DR.

POOL

6820

6844

REC. BLDG

6860

PARKING

6888

6848

POOL

PARKING

6880

6864

6872

6884

6852

6876

6868

MAINT SHED

34-010

S. D. F. D. PRE-FIRE PLAN (1-80)

1. Brentwood Condos
2. 6800 Hyde Park Dr.
3. Condominiums
E-34, 31, LM-12, TLM-11, HE 7, B-10
5. Entrance on Hyde Park Dr.

FIRE PROTECTION SYSTEMS

6. SPRINKLERED: YES ☐ NO ☒
7. AREA SPRINKLERED:
8. F.D. CONNECTION: None
9. STANDPIPE: YES ☒ NO ☐
10. TYPE: FSS (WET) DRY
OTHER:
11. F.D. CONNECTION: None
12. OUTLET LOCATION: Outside each condo door in bldgs 6812 + 6816 (3 story units)

STRUCTURAL ASPECTS

13. HEIGHT: 2 + 3 Story
14. SQ. FOOTAGE: Varies
15. ROOF: Hot mop w/ rock TRUSS ☐
CONVENTIONAL ☒
16. WALLS: Wood Frame - Stucco
17. FLOOR: Slab
18. BASEMENT: YES ☐ NO ☒
19. PENTHOUSE: YES ☐ NO ☒
20. ELEVATOR: YES ☐ NO ☒

UTILITIES

21. GAS Shutoff Bldg. 6828 for pool
22. ELECTRIC ends of bldg.s or in car port
WATER In front of buildings
OTHER
22. NAME Property Management Consultants Inc.
23. EMERGENCY NO. 569-2832 Ans. Serv.

24. HAZARDS: Condos 6812, 6816, 6824, 6832, 6836 are built over carports - Truck maneuvering difficult

25. LOCK BOX: YES ☐ NO ☒ LOCATION:
1ST. UNIT ARRIVAL: Determine location and direct the units responding.
26. SPECIAL FEATURES: Two hydrants located within Complex
Fire alarm: Local, three pull Stations on car port bldg.s 6812 + 6816 - reset panel inside of Center Carport. 6812 Apts A B C & D / 6816 A B C D E F > ENTER FROM PARK RIDGE BL

1843

DATE: 3-30-95 CAPT. Eiter DIV. B

FD-1012 (2-84)

6800 HYDE PARK DR.
BRENTWOOD APARTMENTS

